

FISCAL NOTE

(Return original and 10 copies)

Bill/Resolution No.: _____ Amendment to: Eng. HB 1367

Requested by Legislative Council Date of Request: 3-21-95

- 1. Please estimate the fiscal impact (in dollar amounts) of the above measure for state general or special funds, counties, and cities.

Narrative:

SEE ATTACHED COPY

- 2. State fiscal effect in dollar amounts:

1993-95		1995-97		1997-99	
<u>Biennium</u>		<u>Biennium</u>		<u>Biennium</u>	
<u>General</u>	<u>Special</u>	<u>General</u>	<u>Special</u>	<u>General</u>	<u>Special</u>
<u>Fund</u>	<u>Funds</u>	<u>Fund</u>	<u>Funds</u>	<u>Fund</u>	<u>Funds</u>

Revenues:

Expenditures: THE FISCAL EFFECT ON THE STATE IS UNKNOWN.


- 3. What, if any, is the effect of this measure on the appropriation for your agency or department:

- a. For rest of 1993-95 biennium: NONE
- b. For the 1995-97 biennium: \$20,000
- c. For the 1997-99 biennium: MINIMAL

- 4. County and City fiscal effect in dollar amounts:

1993-95		1995-97		1997-99	
<u>Biennium</u>		<u>Biennium</u>		<u>Biennium</u>	
<u>Counties</u>	<u>Cities</u>	<u>Counties</u>	<u>Cities</u>	<u>Counties</u>	<u>Cities</u>

If additional space is needed, attach a supplemental sheet.


Signed 

Typed Name DONALD D. MUND

Date Prepared: 3-22-95

Department FACILITY MANAGEMENT

Phone Number 328-2471



Facility Management

600 E. BOULEVARD - 4TH FLOOR
BISMARCK, NORTH DAKOTA 58505-0130
Information: 701-328-2471
FAX #: 701-328-3230
A DIVISION OF THE OFFICE OF MANAGEMENT AND BUDGET

"AMENDMENT TO"

HOUSE BILL 1367 - SMOKING AREAS

The fiscal impact of HB1367 will vary greatly from building to building.

The primary concern is with the language that states: "Smoking area" means a clearly designated area in which smoking is permitted and which is separate from any area in which smoking is not permitted. This language will still require a self contained room where smoking is permitted.

In most buildings the best option for exhausting smoke fumes is directly outside. Either through a roof vent or being able to tie into an existing exhaust system that would be exhausting directly to the outside.

The cost for an existing area containing 225 square feet and providing an exhaust system to the outside would be between \$1,500.00 to \$3,000.00. The \$1,500.00 price would provide new ventilation equipment and tie into an existing exhaust system that would ventilate through the roof. The cost would double if we have to make a new penetration to the outside in order to exhaust the smoking room. These costs will then be multiplied by the number of designated areas that may be set up within the various governmental buildings located within the state of North Dakota.