

CHAPTER 45-12-06

MINIATURE BOILERS - NEW INSTALLATIONS

Section

45-12-06-01 Requirements

45-12-06-01. Requirements.

1. All new boilers, except those exempt by law, to be installed in North Dakota must be reported to the chief boiler inspector by the owner or user and by the installer.
2. A miniature boiler, except one exempt by law, may not be installed in North Dakota unless it has been constructed, inspected, and stamped in conformity with section I of the American Society of Mechanical Engineers Code and is approved, registered, and inspected in accordance with this article.
3. A miniature boiler having the standard stamping of another state that has adopted a standard of construction equivalent to the standard of North Dakota may be accepted by the inspector. However, the person desiring to install the same shall make application for the installation and shall file with this application the manufacturer's data report covering the construction of the boiler in question.
4. All new installation boilers, including reinstalled boilers, must be installed in accordance with the requirements of the American Society of Mechanical Engineers Code and these regulations.

History: Effective June 1, 1994.

General Authority: NDCC 26.1-22.1-14

Law Implemented: NDCC 26.1-22.1-14