

**CHAPTER 45-12-08**  
**HEATING, LOW PRESSURE, AND HOT WATER SUPPLY BOILERS - NEW**  
**INSTALLATIONS**

Section

45-12-08-01      Requirements

**45-12-08-01. Requirements.**

1. Unless exempt by this article, a heating or low pressure boiler may not be installed in this state unless it has been constructed, inspected, and stamped to conform with section IV of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code and is approved, registered, and inspected in accordance with the requirements of this article.
2. All new installation boilers, including reinstalled boilers, must be installed in accordance with the requirements of the American Society of Mechanical Engineers Code and this article.
3. Hot water supply boilers may not be installed unless constructed and approved in accordance with the American gas association, the American national standards institute, or the American society of mechanical engineers.
4. All new boilers, except those exempt by law, to be installed in North Dakota must be reported to the chief boiler inspector by the owner or user, and by the installer.

**History:** Effective June 1, 1994.

**General Authority:** NDCC 26.1-22.1-14

**Law Implemented:** NDCC 26.1-22.1-14